

ON 13/18

(This is a reprint of Operating Notice 14/17 issued 27Feb2017)

Pendre Yard Lighting

The low energy yard lights do not have sensors, so have to be manually activated by pushing one of the buttons situated at the locations listed below. One operation of a button will give 20 minutes of light, which should be sufficient to move safely through the yard after locking up, or to move from location to location.

Push-buttons are situated:

1. On the left hand edge of the south side of the water column.
2. In the Locomotive Shed doorway, just north of the doors, on the stone pillar and to the right of the existing shed light switch.
3. In the West Carriage Shed, on the north wall, left of the side door adjoining the Block post and on the same box as the shed light control.
4. In the North Carriage Shed, to the south of the west end double doors, mounted on the steel column which frames the doors.
5. In the Paintshop lobby, alongside the external door frame, just above and to the right of the existing light switches.
6. In the South Carriage Shed, on the north wall and to the north of the wicket door, at the west end of the shed.

A switch is provided in the Blockpost to turn the lights on during shunting. Once operated the lights will remain on until the switch is turned off again, so it is essential that this is not forgotten once a shunt is over.

DJ Scotson
Operating Manager
06 February 2018

DJS/PMK